



September 15, 2021

Mrs. Patricia Van Gerpen
Executive Director
Public Utilities Commission
500 East Capitol Avenue
Pierre, SD 57501

RE: *In the Matter of the Application by Tatanka Ridge Wind, LLC for a Permit of a Wind Energy Facility in Deuel County, South Dakota – Order Granting Extension for Compliance with Condition 29 – EL19-026*

Bi-Monthly Update #10: September 1 – September 15, 2021

Dear Mrs. Van Gerpen:

Tatanka Ridge Wind, LLC (Tatanka Ridge Wind) respectfully submits this filing in compliance with the Order granting an extension to Condition 29 of the Facility Permit.

Condition 29:

Within 90 days after the Project's commercial operation date, Applicant shall submit a report to the Commission that provides the following information:

- a) as-built location of structures and facilities, including drawings clearly showing compliance with the setbacks required by state and local governments;
- b) the status of remedial activities for road damage, landowner property damage, crop damage, environmental damage, or any other damage resulting from Project construction activities; and
- c) a summary of known landowner complaints and Applicant's plan for resolving those complaints.

On April 16, 2021, the Commission granted Motion for Extension to Comply with Condition 29 until August 5, 2021. Applicant shall provide updates to Staff on a bi-monthly basis, to be provided on the Fifteenth and Thirtieth of each month.

Response to part a:

The civil as-built survey is complete. Attached please find the as-built layout demonstrating compliance with setbacks.

- Participating Residence Setback = 1,500 feet (ft)
- Non-Participating Residence Setback (4*TH) = 1,996 ft
- Public Road Setback (1.1 TH) = 549 ft
- Non-Participating Property Setback (1.1 TH) = 549 ft
- Toronto Municipal Setback = 1.5 miles

All turbines are in the permitted locations, except for the shifts of less than 200 ft for Turbines E2, F2, G1, G2, G3, I4, and P3 as described in Condition 22 filing on March 20, 2020 and Turbines K0, L1, and S6 as described in Condition 22 filing on May 14, 2020. Please note that Turbine I3 was kept in the permitted location per landowner request, instead of the 21.3 ft shift identified in the March 20, 2020 filing.

Several turbines appear close to the setback due to scale on the attached map. To provide additional detail on those turbines:

- Turbine S6 is located 10 ft east of the road setback
- Turbine K0 is 42 ft outside of the participating residence setback and is 1,377 ft to the interstate ROW.
- Turbine L1 is 7 ft outside of the non-participating residence setback.

Response to part b:

Road repairs are completed. The Townships and State have accepted the current road conditions. Deuel County has provided feedback on the road conditions and we are working together to come to a resolution on responsibilities and costs.

There is no known environmental damage or property damage due to construction.

Response to part c:

Tatanka Ridge Wind, LLC and the construction team have not identified any new issues this period with landowners and have resolved outstanding issues.

Please let me know if you have any additional questions (mark.croissant@avangrid.com).

Sincerely,

Mark Croissant

Mark Croissant
Senior Project Manager – Projects

Attached: Tatanka_AsBuilt_Project_Facilities_w_Setbacks_11x17_20210913.pdf